

X-ray position-sensitive duo-lateral diamond detectors at SOLEIL

Kewin Desjardins, Michel Bordessoule, Michal Pomorski

► **To cite this version:**

Kewin Desjardins, Michel Bordessoule, Michal Pomorski. X-ray position-sensitive duo-lateral diamond detectors at SOLEIL. *Journal of Synchrotron Radiation, International Union of Crystallography*, 2018, 25 (2), pp.399 - 406. 10.1107/S1600577517016769 . cea-01773744

HAL Id: cea-01773744

<https://hal-cea.archives-ouvertes.fr/cea-01773744>

Submitted on 10 Jan 2019

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

X-ray position-sensitive duo-lateral diamond detectors at SOLEIL

Kewin Desjardins,^{a*} Michel Bordessoule^a and Michal Pomorski^b


^aSynchrotron SOLEIL, Saint-Aubin, 91192 Gif-sur-Yvette, France, and ^bCEA-LIST, Diamond Sensors Laboratory, 91191 Gif-sur-Yvette, France. *Correspondence e-mail: kewin.desjardins@synchrotron-soleil.fr

The performance of a diamond X-ray beam position monitor is reported. This detector consists of an ionization solid-state chamber based on a thin single-crystal chemical-vapour-deposition diamond with position-sensitive resistive electrodes in a duo-lateral configuration. The detector's linearity, homogeneity and responsivity were studied on beamlines at Synchrotron SOLEIL with various beam sizes, intensities and energies. These measurements demonstrate the large and homogeneous (absorption variation of less than 0.7% over $500\ \mu\text{m} \times 500\ \mu\text{m}$) active area of the detector, with linear responses independent of the X-ray beam spatial distribution. Due to the excellent charge collection efficiency (approaching 100%) and intensity sensitivity (0.05%), the detector allows monitoring of the incident beam flux precisely. In addition, the in-beam position resolution was compared with a theoretical analysis providing an estimation of the detector's beam position resolution capability depending on the experimental conditions (X-ray flux, energy and readout acquisition time).

Keywords: X-ray beam position monitor; XBPM; PSD; diamond detector; noise analysis.

1. Introduction

Currently, X-ray beam position monitors are an essential element for synchrotron beamlines that focus the beam down to a few micrometres or less, like the long beamlines using a nano-size X-ray beam for large two-dimensional scan sample mapping (Somogyi *et al.*, 2015). In order to precisely monitor the intensity and adjust the position of the X-ray beams, such beamlines need a fast X-ray diagnostic inserted permanently into the beam (with low absorption and radiation hardness). Many different kinds of in-beam transparent position monitors have been used in the past: microwire devices (Heald, 1986), gaseous detectors (Schildkamp & Pradervand, 1995), indirect fluorescent or scattered X-ray detection from thin foils with PIN-diodes (Alkire *et al.*, 2000) or pixelated detectors (Rico-Alvarez *et al.*, 2014), as well as thin solid-state devices developed on silicon (Fuchs *et al.*, 2007) or polycrystalline diamond (Bergonzo *et al.*, 1999). In this paper, a new type of diamond X-ray beam position monitor (XBPM) is presented: the device is based on an electronic-grade single-crystal chemical-vapour-deposition (CVD) diamond material (Morse *et al.*, 2010) processed on a duo-lateral position-sensitive detector (PSD) with diamond-like carbon (DLC) resistive coating (Pomorski *et al.*, 2009). In addition to the excellent physical properties of diamond (radiation hardness, low X-ray absorption, mechanical resistance, large band gap, fast speed charge propagation, *etc.*), this detector also has several other advantages compared with the classical quadrant XBPM design (Desjardins *et al.*, 2013) or the strip detector (Shu *et al.*, 1998, Zhou *et al.*, 2015): a very large active surface (usable with X-ray beams from millimetre to sub-micrometre



sizes), easier to calibrate, and a simplified fabrication process. *i.e.* it does not need any photolithography or precise coating processes. Furthermore, the PSD is an all-carbon device; therefore it represents a good solution for low-energy applications (Desjardins *et al.*, 2014; Gaowei *et al.*, 2015). However, the possible disadvantages, with respect to the quadrant detector, come from the PSD resistive coating, which generates an additional noise source and makes it slower due to the higher RC constant. In this paper, the fabrication of a PSD diamond detector is described, the advantages are presented with experimental results, and the intensity and position monitoring performances are demonstrated.

2. PSD duo-lateral design

The PSDs were made from high-quality [100]-oriented electronic-grade single-crystal CVD diamonds from Element Six Ltd (<http://www.e6.com>) (freestanding windows, type IIa with ~ 1 p.p.m. nitrogen, 4.50 mm \times 4.50 mm) with a thickness of 50 μm down to 20 μm supplied by ALMAX easyLab (<http://www.almax-easylab.com>). All plates were previously controlled by cross-polarized microscopy (Hoa *et al.*, 2014) to check that there are no dislocations or other structural defects in the active area frequently rendering diamond devices unstable (Muller *et al.*, 2009). The thickness was measured at SOLEIL by Fourier-transform infrared spectroscopy techniques with a Raman spectroscopy microscope on the SMIS beamline (Dumas *et al.*, 2006) in order to check the homogeneity and parallelism. Additionally, the diamond thickness measurement provides information on the X-ray beam absorption for each detector (Fig. 1). After hot-acid cleaning, both sides of the plates were sputtering-coated with DLC using a simple mask with an opening window of 4 mm \times 4 mm, eliminating the need for photolithography. This carbon coating constitutes a resistive layer with the impedance controlled by the deposition time, approximately 100 k Ω with a thickness of ~ 200 nm. The two pairs of collecting electrodes at the extremities of both sides were made by sputtering of Ti/Au (~ 200 nm) layers using a shadow mask (lateral size of 4 mm \times 0.25 mm by electrode). These two electrodes pairs are mutually perpendicularly positioned and the distance between the electrodes of each pair is 3.5 mm.




Figure 1
Theoretical X-ray absorption of diamond with thicknesses of 50 μm (red curve) and 20 μm (blue curve).

The free charge carriers (electron–hole pairs) generated by the X-ray beam interaction in the diamond drift under the influence of the applied electric field created by the externally biased surface electrodes, thus generating an electric current in the external circuit (Fig. 2). In the DLC resistive layer, these charges are divided between the two electrodes on both surfaces; therefore the X-ray beam position (as defined by the centre of gravity of the beam) is directly obtained from the corresponding currents and the PSD dimensions as written in equation (1),

$$X = K_x \frac{I_{x1} - I_{x2}}{I_{x1} + I_{x2}}, \quad Y = K_y \frac{I_{y1} - I_{y2}}{I_{y1} + I_{y2}}, \quad (1)$$

where x and y are coordinates of the position of the X-ray beam center, K_x and K_y are the scale factors equal to $L/2$ with L the distance between collecting electrodes, and $I(x_{1,2}$ or $y_{1,2})$ is the signal collected from the horizontal (x) and vertical (y) electrode pairs, respectively.

The total intensity is given by the sum of the signal collected from one of the electrode pairs (*i.e.* $I_t = |I_{x1} + I_{x2}| = |I_{y1} + I_{y2}|$) and is directly proportional to the part of the absorbed X-ray beam [assuming a total charge collection efficiency equal to 100%]. It can be estimated from equation (2),

$$I_t = q \frac{E_{\text{ph}}}{\varepsilon_p} A(E_{\text{ph}}) \Phi, \quad (2)$$

where I_t is the total current produced by the XBPM, q is the value of the electron charge, E_{ph} is the incident-beam energy, $\varepsilon_p = 13.25 \pm 0.5$ eV is the electron–hole pair creation energy (Keister & Smedley, 2009) for X-ray absorption in diamond, A is the absorption factor depending on the energy E_{ph} and diamond thickness, and Φ is the X-ray beam flux.




Figure 2
Schematic diagram of the duo-lateral PSD. Inter-electrode area, $L \times L$, with orthogonal opposed electrode on the front and back sides. Four current-to-voltage amplifier channels with bias applied to the back side. C_D , R_D and I_{intr} are, respectively, the capacitance, the impedance and the leakage current of the single-crystal CVD diamond.




Figure 3
 (a) XBPM PSDs. (b) Active area with DLC and two electrodes wire-bonded. (c) XBPM PSD series (50 μm down to 20 μm thickness) mounted on boards.

3. PSD diamond results

3.1. Experimental set-up and electronics

Several PSDs (Fig. 3a) were mounted on specific ceramic boards where the electrodes were connected with aluminium wedge wire bondings (Figs. 3b, 3c). One of these XBPMs was mounted on the GALAXIES beamline (Céolin *et al.*, 2013) and tested at an energy of 6.2 keV with a high photon flux of 1.7×10^{13} photons s^{-1} and a small beam spot of $30 \mu\text{m} \times 90 \mu\text{m}$. Two other PSDs have been installed on the METROLOGIE (Idir *et al.*, 2006) and SIRIUS beamlines (Ciatto *et al.*, 2016) for spatial resolution measurements with beam energies of 7 keV and 2.6 keV, respectively, and photon fluxes down to 10^{10} photons s^{-1} . Finally, a micro beam position reconstruction capability has been demonstrated with an X-ray beam focused by a zone plate ($1 \mu\text{m} \times 1 \mu\text{m}$) on the NANOSCOPIUM beamline (Somogyi *et al.*, 2015) with a beam energy of 12 keV and a flux of 10^{10} photons s^{-1} .

Each pair of PSD electrodes (X and Y) were connected to the current-to-voltage amplifier (IV-amp) LOCUM-4F (ENZ, <http://www.enz-de.de>). This IV-amp has four channels for measuring simultaneously the four low currents (ranging from 1 mA down to 100 pA), and it is particularly adapted for PSD use with a splitter bias, which is able to apply a voltage only to one side of the PSD (X electrodes in Fig. 2), while the two other channels remain connected to the main ground (0 V) potential (Y electrodes in Fig. 2). However, the front-end circuit of the LOCUM is not specified in terms of noise. Finally, the IV-amp output voltages were digitized by an analog-to-digital convertor (ADC Adlink 2005, <http://www.adlinktech.com>) and recorded by TANGO control applications (<http://www.tango-controls.org>)

3.2. Detector calibration

The PSD position calibration factors (or scale factors) were determined experimentally by translating the detector linearly in the X-ray beam, recording the four currents (Fig. 4a) and plotting values of difference/sum currents *versus* the position (Fig. 4b). The results were fit by equation (1) in the central region for both directions to give the two scale factors (K_x and K_y). This experimental result assures excellent position reconstruction and compensation for fabrication defects or angle misalignment. In comparison with the classical

diamond quadrant XBPM, these calibration factors are stable and do not depend on the spatial X-ray beam distribution. A comparison between the vertical calibration factors obtained for the different beam sizes (as defined by slits) with the PSD device (green curve) and quadrant detector (blue line) for the same in-beam conditions is shown in Fig. 5. An additional measurement has also been performed with a focused X-ray




Figure 4
 (a) Measured PSD currents *versus* XBPM displacement through the beam in the vertical direction: vertical currents (top) and horizontal currents (bottom). (b) Measured PSD difference over the sum currents *versus* XBPM displacement in the vertical direction and linear fit residual.




Figure 5
Comparison between the calibration factors obtained with the quadrant XBPM (blue line) and the PSD XBPM (green line) for different X-ray beam sizes. The scale factor of the quadrant XBPM depends linearly on beam size. The scale factor of the PSD is stable.

beam ($1 \mu\text{m} \times 1 \mu\text{m}$) on the NANOSCOPIUM beamline (Fig. 6). It allows demonstration of the beam position reconstruction with very small beam over a large area (1 mm) which is not a simple task with a classical quadrant detector (Bergonzo *et al.*, 1999).

Therefore, the reconstructed position could be measured independently of the experimental conditions (energy, slit gap, focused or unfocused beam, *etc.*).

3.3. Flux and intensity monitoring capabilities

The total charge collection efficiency was verified on the METROLOGIE beamline by measuring the X-ray beam-induced current (XBIC) as a function of the bias voltage, as shown in Fig. 7. Like the other diamond XBPMs made with electronic-grade single-crystal CVD (Desjardins *et al.*, 2013), a potential of a few Volts ($>0.2 \text{ V } \mu\text{m}^{-1}$) is enough to reach constant XBIC values. Thereby, the flux can be easily calculated as equation (2).

The dark current depends on the PSD inter-electrode resistance (R_{ie}), the temperature and the input voltage offsets of the operational amplifier. Its intensity is rather high with low resistance but significantly lower ($<1 \text{ nA}$) with $R_{ie} >$




Figure 6
The PSD reconstructed position of a linear movement over 1 mm with a $1 \mu\text{m}$ X-ray beam (flux $\simeq 10^{10}$ photons s^{-1}).




Figure 7
Top: PSD X-ray beam-induced current (XBIC) versus detector bias. Bottom: PSD dark current versus detector bias.

$100 \text{ k}\Omega$. However, the stable dark currents do not influence the position measurement precision, due to the easily applicable corrections. On the other hand, at low X-ray fluxes, the photocurrent reaches offset levels, thereby defining a reasonable usability limit for this detector. Furthermore, these dark currents may be subtracted from each current for efficient estimation of the incident X-ray photon flux.

The XBPM intensity monitoring capability has been evaluated on the GALAXIES beamline, and the obtained sensitivity is illustrated in Fig. 8 with a low XBIC fluctuation. The perfect visualization of the top-up filling mode of the storage ring at SOLEIL (with 0.5% electron re-injection every few minutes) can be seen, which is in excellent agreement with silicon diode measurements (error $<0.05\%$).

The homogeneity is determined on the METROLOGIE beamline (flux $\simeq 10^{10}$ photons s^{-1}) from a two-dimensional scan which is plotted in Fig. 9 with an observed signal variation below 0.7% over $500 \mu\text{m} \times 500 \mu\text{m}$ of active area. This is clearly attributable to the thickness non-uniformity of the diamond plate corresponding here to a peak-to-peak thickness difference of 300 nm at an X-ray energy of 7 keV.




Figure 8
Time scan showing the top-up mode of operation of the SOLEIL storage ring with a re-injection at $t = 30 \text{ s}$. XBPM PSD diamond (blue) and the corresponding downstream Si photodiode (red) current signals.




Figure 9
Total current, I_t , map made over the central area ($500 \mu\text{m} \times 500 \mu\text{m}$) of the PSD (X-ray energy of 7 keV and flux $\simeq 10^{10}$ photons s^{-1}).

Hence, the intensity and flux can be easily measured independently of the X-ray beam characteristics (energy, spatial distribution, focused or unfocused beam, *etc.*).

3.4. Beam position monitoring capabilities

A first and simple demonstration of the PSD position measurement capability consisted of the reconstruction of the position for small PSD displacements with a high beam flux ($>10^{13}$ photons s^{-1}) on the GALAXIES beamline (Fig. 10). Beam displacements of 5 μm , 1 μm , 500 nm and 100 nm could be reconstructed under these conditions (ADC integration time of 100 ms, LOCUM-4F bandwidth = 2.5 kHz, total XBIC = 140 μA) with a standard deviation of 50 nm r.m.s. (when the beam is assumed to be stable).

To understand the noise contributions associated with a beam position measurement, a model is proposed where the instrumental noise is distinguished from the photonic noise and X-ray beam noise. Also, this model is compared with the measurement from a large range of X-ray beam currents.

In equation (1), the position P on an axis (X or Y) is defined by the ratio of the difference over the sum of currents. In




Figure 10
Diamond PSD reconstructed position for very small displacements: 5 μm , 1 μm , 0.5 μm and 0.1 μm (X-ray energy of 6.2 keV and flux $\simeq 10^{13}$ photons s^{-1}).

Table 1

Sources of noise for each PSD current and their correlation.

Independent noise	$\sigma_{0I1}^2, \sigma_{0I2}^2$ are composed of the low amplifier self-noise, σ_{amp}^2 , and the ADC noise, σ_{adc}^2 .
Correlated noise	σ_{co}^2 results from the X-ray beam flux noise (unmodelled), the eddy currents (unmodelled) and the shot noise σ_{id}^2 and σ_{c}^2 of the difference and sum currents, respectively.
Anti-correlated noise	σ_{ac}^2 is a combination of the unmodelled noise from the X-ray beam vibration (σ_{bv}^2) and the dominant noise (σ_{Ric}^2) caused by the resistive (R_{ic}) coupling of the IV-amp's inputs. This noise has not been analyzed here (Van Esch <i>et al.</i> , 2004).

equation (3), we denote D for the differential current ($I1 - I2$) and C for the common-mode current ($I1 + I2$) crossing the detector; the scale factor is now denoted K ,

$$P = K \frac{D}{C}. \quad (3)$$

In the following text, μ refers to a mean and σ to a standard deviation. For instance, the position P has a mean, μ_p , and a variance, σ_p^2 , given in equation (4). The latter derives from the variance of the ratio D/C (Seltman, 2017). It is further shown that the covariance, σ_{dc}^2 , is small,

$$\sigma_p^2 = \frac{\mu_d^2}{\mu_c^2} \left[\frac{\sigma_d^2}{\mu_d^2} + \frac{\sigma_c^2}{\mu_c^2} - 2 \frac{\sigma_{\text{dc}}^2}{\mu_d \mu_c} \right]. \quad (4)$$

σ_d^2 and σ_c^2 are, respectively, the difference and the sum noises and are given in equations (7) and (9); σ_{dc}^2 is the covariance between D and C .

Also, each PSD current has a noise, which is the sum of the correlated and independent noise, and is written as

$$\sigma_{I1}^2 = \sigma_{0I1}^2 + \sigma_{\text{co}}^2 + \sigma_{\text{ac}}^2, \quad \sigma_{I2}^2 = \sigma_{0I2}^2 + \sigma_{\text{co}}^2 + \sigma_{\text{ac}}^2, \quad (5)$$

where the different types of noise are described in Table 1.

In practice, each electronic channel is similar ($\sigma_{0I1}^2 = \sigma_{0I2}^2 = \sigma_0^2$) and the associated electronic noise is very low (<1 pA $\text{Hz}^{-1/2}$) compared with the other noise sources, which implies that the covariance ($\sigma_{\text{dc}}^2 = \sigma_{0I1}^2 - \sigma_{0I2}^2$) is negligible. Furthermore, if the beam is centred ($\mu_p = 0$), the term σ_c^2 in equation (4) vanishes, and the expression of the position noise reduces to equation (6),

$$\sigma_p = K \frac{\sigma_d}{\mu_c}. \quad (6)$$

Hence, the centred position noise is proportional to the differential noise, and inversely proportional to the detector current. The differential noise, σ_d^2 , is modelled according to equation (7),

$$\sigma_d^2 = [\sigma_{\text{id}}^2 + 4\sigma_{\text{ac}}^2] H1(f)^2 + \sigma_{\text{adc}}^2, \quad (7)$$

where σ_{id}^2 is the current noise, σ_{ac}^2 is the anti-correlated noise (Table 1), $\sigma_{\text{adc}}^2 = 11$ fA $\text{Hz}^{-1/2}$ is the ADC quantization noise, which appears to be partially correlated, likely due to some clock jitter, and $H1(f)$ is the module of the trans-impedance amplifier frequency response [equation (8)],

$$H1(f) = \left\{ [1 + (f/F1)^2][1 + (f/F2)^2] \right\}^{-1/2}. \quad (8)$$

Table 2

Detector characteristics, beamline experimental conditions, acquisition characteristics and the parameters of the noise model used.

PSD	Diamond thickness 26 μm , $R_{ic}(X) = 25 \text{ k}\Omega$ and $R_{ic}(Y) = 45 \text{ k}\Omega$
X-ray beam	METROLOGIE beamline (bending magnet), $10^8 \text{ photons s}^{-1}$ to $10^{10} \text{ photons s}^{-1}$ and $E_{ph} = 7 \text{ keV}$
IV-amp	LOCUM-4F with $I_{range} = 100 \text{ nA}$ [i.e. RF = 100 M Ω , output = 1 V nA $^{-1}$ and BP (3dB) = 360 Hz]
IV-amp filter parameters [equation (8)]	$F1 = 230 \text{ Hz}$ and $F2 = 2800 \text{ Hz}$
ADC	ADC Adlink 2005 with sampling frequency $F_s = 200 \text{ kHz}$ ($F_{Nyq} = 100 \text{ kHz}$), 16 bit with noise of 2 bit (dynamic 14 bit)
ADC noise	$\sigma_{adc} = I_{range} / [2^{14} (12 F_{Nyq})^{1/2}] = 10 \text{ fA Hz}^{-1/2}$
Anti-correlated noise model fitted	$\sigma_{ac} = 1.8 \text{ pA Hz}^{-1/2} + (10 \text{ pA Hz}^{-1/2} / f^{-1/2})$.

As we wanted to consider the sum noise (σ_c^2) in this study, we give it in equation (9),

$$\sigma_c^2 = [\sigma_{ic}^2] H1(f)^2 + 2\sigma_{adc}^2. \quad (9)$$

The shot noise (Spear, 2005) difference, σ_{id}^2 , and sum, σ_{ic}^2 , remain to be defined in equations (10) and (11) to complete this noise model,

$$\sigma_{id}^2 = 2q\mu_d(\text{FF} + E_{ph}/\varepsilon_p), \quad (10)$$


$$\sigma_{ic}^2 = 2q\mu_c(\text{FF} + E_{ph}/\varepsilon_p), \quad (11)$$

where q is the value of the electron charge, E_{ph} is the energy of the incident beam, $\varepsilon_p = 13.25 \pm 0.5 \text{ eV}$ is the electron-hole pair creation energy for X-ray absorption in diamond, and $\text{FF} = 0.08$ is the Fano factor of diamond.

This established model was compared with a series of noise density measurements performed on the METROLOGIE beamline. A diamond PSD was irradiated with different X-ray fluxes ($10^8 \text{ photons s}^{-1}$ to $10^{11} \text{ photons s}^{-1}$) by insertion of various metallic absorbers into the beam. The ADC sampling frequency was 200 kHz with an integration time of 1 s which allows the acquisition of 200000 samples per measurement. The LOCUM current range (I_{range}) was adapted to the XBIC level. At every flux level, varying the corresponding total PSD current between 4 nA and 130 nA, 20 spectra corresponding to the fast Fourier transfer of the ADC data were successively acquired. Table 2 summarizes the detector characteristics, the experimental conditions and the parameters of the noise model used.

Figs. 11(a) and 11(b) give examples of two acquired spectra for a total photocurrent of $\mu_c = 88.1 \text{ nA}$ for the sum and difference, respectively, in comparison with the models given by equations (7) and (9).

Excess noise appears in the sum noise (Fig. 11a) as peaks (50 Hz and 70 Hz). This noise does not come from the amplifier, because its variance is proportional to the total current. This is a flux noise, which will not be converted as position noise [equation (6)]. Similarly, in the difference noise (Fig. 11b), the harmonic frequencies from the local electrical

**Figure 11**

(a) Measured and model of the sum of the current density spectrum. (b) Measured and model of the difference of the current density spectrum. The blue lines are the measurement, the red lines are the models of σ_c^2 and σ_d^2 . The green dashed line is σ_{adc}^2 and the magenta dashed line is the shot noise, σ_{ic}^2 and σ_{id}^2 . The total current is $\mu_c = 88 \text{ nA}$ and $\mu_d = 0.6 \text{ nA}$.

supply network are present. This defect comes from the amplifier. This noise will be converted as position noise.

With these observations, and knowing that the current difference shot noise (σ_{id}^2) and the beam vibration noise (σ_{bv}^2) are both low, the difference noise is considered constant. The position noise is then calculated from equations (6) and (7) and compared in Fig. 12 for two incident X-ray fluxes. The position noise is always the same shape, with the intensity proportional to the total current, as stated in equation (6).

Finally, it is possible to trace a complete diagram giving the theoretical PSD limit of the position resolution as a function of the X-ray beam-induced current (depending on the diamond thickness, the beam flux and energy used) and the acquisition bandwidth. In Fig. 13 we have compiled the measurement results obtained for a bandwidth of 40 Hz at the METROLOGIE and SIRUS beamlines obtained with two different PSD devices and compare it with the presented model. The corresponding result obtained at the GALAXIES beamline and presented in Fig. 10 is also included. All of these demonstrate excellent accordance with the theoretical model.

4. Conclusion

The feasibility of building a duo-lateral position-sensitive detector based on CVD diamond has been demonstrated in




Figure 12
Two measured position noise density spectra compared with their models with total currents of $\mu_c = 88.1$ nA (blue and red) and $\mu_c = 5$ nA (green and purple).

this paper. Its excellent capabilities of intensity and flux monitoring on the same level as the more common diamond quadrant XBPMs have been confirmed. Additionally, the various advantages of PSDs have been shown, such as their simpler position calibration, and the large active area for both large and very small beam dimensions. The PSDs are particularly adapted to beamlines where the X-ray beam spatial distribution could be modified during the experiment (*i.e.* during energy scans and monochromator movements) or for synchrotron beamlines which do not use a position feedback device. The principal drawbacks linked to the noise sources have been discussed and a theoretical model has been compared with measured data, which permit the optimization of the diamond PSD knowing the experimental beamline conditions (*i.e.* energy, incident flux and especially the beam




Figure 13
Position resolution measured *versus* the theoretical model for different PSD and X-ray beam fluxes. The blue, red and violet dots represent the measured PSD resolution (sum of position noise density between 10 Hz to 40 Hz) obtained on the METROLOGIE and SIRIUS beamlines, respectively, for different incident fluxes. The green dot shows a similar measurement obtained on the GALAXIES beamline corresponding to the measurement standard deviation when the beam is stable (Fig. 10). The lines are the calculated theoretical limits of the reconstructed position for these PSDs, the beamline configurations and the acquisition bandwidth.

position precision measurement needed in the sample) with a compromise between the expected generated X-ray beam current, the XBPM absorption and desired readout acquisition speed.

Finally, PSD diamond XBPMs have been installed on 12 beamlines at Synchrotron SOLEIL and at two other synchrotrons (NSLSII and SSRF). Additionally, a very thin device has been made (CVD diamond of 4 μm thickness) for the SIRIUS beamline at SOLEIL for use in the tender X-ray range in order to upgrade the previously installed thin quadrant diamond detector.

Acknowledgements

We would like to thank the GALAXIES, SIRIUS, NANO-SCOPIUM and particularly the METROLOGY beamline teams for their support and beam time necessary for the characterization of the PSD XBPM.

References

- Alkire, R. W., Rosenbaum, G. & Evans, G. (2000). *J. Synchrotron Rad.* **7**, 61–68.
- Bergonzo, P., Brambilla, A., Tromson, D., Marshall, R. D., Jany, C., Foulon, F., Gauthier, C., Solé, V. A., Rogalev, A. & Goulon, J. (1999). *J. Synchrotron Rad.* **6**, 1–5.
- Céolin, D., Ablett, J. M., Prieur, D., Moreno, T., Rueff, J. P., Marchenko, T., Journel, L., Guillemin, R., Pilette, B., Marin, T. & Simon, M. (2013). *J. Electron Spectrosc. Relat. Phenom. B*, **190**, 188–192.
- Ciatto, G., Chu, M. H., Fontaine, P., Aubert, H., Renevier, H. & Deschanvres, J. L. (2016). *Thin Solid Films*, **617**, 48–54.
- Desjardins, K., Duran, D., Hustache, S., Pomorski, M. & Shepard, W. (2013). *J. Phys. Conf. Ser.* **425**, 212004.
- Desjardins, K., Pomorski, M. & Morse, J. (2014). *J. Synchrotron Rad.* **21**, 1217–1223.
- Dumas, P., Polack, F., Lagarde, B., Chubar, O., Giorgetta, J. L. & Lefrançois, S. (2006). *Infrared Phys. Technol.* **49**, 152–160.
- Fuchs, M. R., Holldack, K., Reichardt, G. & Mueller, U. (2007). *AIP Conf. Proc.* **879**, 1006–1009.
- Heald, S. M. (1986). *Nucl. Instrum. Methods Phys. Res. A*, **246**, 411–412.
- Ho, L. T. M., Ouisse, T., Chaussende, D., Naamoun, M., Tallaire, A. & Achard, J. (2014). *Cryst. Growth Des.* **14**, 5761–5766.
- Idir, M., Mercère, P., Moreno, T. & Delmotte, A. (2006). *Synchrotron Radiat. News*, **19**, 18–23.
- Keister, J. W. & Smedley, J. (2009). *Nucl. Instrum. Methods Phys. Res. A*, **606**, 774–779.
- Gaowei, M., Smedley, J., Zhou, T., Muller, E. & Sumant, A. (2015). *Proceedings of the Sixth International Particle Accelerator Conference (IPAC2015)*, 3–8 May 2015, Richmond, VA, USA.
- Morse, J., Solar, B. & Graafsma, H. (2010). *J. Synchrotron Rad.* **17**, 456–464.
- Muller, E., Smedley, J., Raghothamachar, B., Gaow, M., Keister, J., Ben-Zvi, I., Dudley, M. & Wu, Q. (2009). MRS Online Proceeding Library Archive 1203.
- Pomorski, M., Ciobanu, M., Mer, C., Rebisz-Pomorska, C., Tromson, D. & Bergonzo, P. (2009). *Phys. Status Solidi A*, **206**, 2109–2114.
- Rico-Alvarez, O., Kachatkou, A., Marchal, J., Willis, B., Sawhney, K., Tartoni, N. & Van Silfhout, R. G. (2014). *J. Instrum.* **9**, C12036.
- Schildkamp, W. & Pradervand, C. (1995). *Rev. Sci. Instrum.* **66**, 1956–1959.
- Seltman, H. (2017). *Approximations for Mean and Variance of a Ratio*. Department of Statistics at Carnegie Mellon University, USA.

- Shu, D., Kuzay, T. M., Fang, Y., Barraza, J. & Cundiff, T. (1998). *J. Synchrotron Rad.* **5**, 636–638.
- Somogyi, A., Medjoubi, K., Baranton, G., Le Roux, V., Ribbens, M., Polack, F., Philippot, P. & Samama, J.-P. (2015). *J. Synchrotron Rad.* **22**, 1118–1129.
- Spear, J. D. (2005). *Rev. Sci. Instrum.* **76**, 076101.
- Van Esch, P., Gahl, T. & Guérard, B. (2004). *Nucl. Instrum. Methods Phys. Res. A*, **526**, 493–500.
- Zhou, T., Ding, W., Gaowei, M., De Geronimo, G., Bohon, J., Smedley, J. & Muller, E. (2015). *J. Synchrotron Rad.* **22**, 1396–1402.